

  
**SOUDAL**

# Confirmation

SOUDAL N.V. confirms that the aerosol adhesive with the name:

## SOUDAFOAM FR

Shows low VOC contents as specified in LEED v2009 credit EQ 4.1 (Adhesives and Sealants).

VOC contents is below the limit value specified as 70% VOC's by weight of aerosol adhesives.

|                                      |   |
|--------------------------------------|---|
| Sample identification                | <b>SOUDAFOAM FR</b>   |
| Product type                         | <b>Aerosol adhesive</b>   |
| Product data, according to Soudal NV | No exempt compounds present<br>No water present<br>Density 1,10g/ml |

|                     | Water content<br>(%mass) | VOC less water less<br>exempt compounds (g/l) | VOC limit (g/l) |
|---------------------|--------------------------|---|-----------------|
| <b>SOUDAFOAM FR</b> | 0                        | 429   | 700             |

With this confirmation, use of product SOUDAFOAM FR may qualify for fulfillment of LEED v2009 credit EQ 4.1 (Adhesives and Sealants).

October 15, 2014

Luc Thys  
Director Marketing and R&D

Andrew Swift  
Technical Product Manager

*Use of US Green Building Council Member logo does not imply that USGBC has approved this confirmation or any mentioned product.*